

HB

664

Funding Information
General Fund \$22,250,500
Other Funds -0-
\$22,250,500

Introduced: 2/4/80
Referred: Health, Education &
Social Services and Finance

1 IN THE HOUSE

BY ANDERSON AND OSTERBACK

2 HOUSE BILL NO. 664

3 IN THE LEGISLATURE OF THE STATE OF ALASKA

4 ELEVENTH LEGISLATURE - SECOND SESSION

5 A BILL

6 For an Act entitled: "An Act making a special appropriation to the Depart-
7 ment of Transportation and Public Facilities for school
8 construction and upgrade at various locations; and
9 providing for an effective date."

10 BE IT ENACTED BY THE LEGISLATURE OF THE STATE OF ALASKA:

11 * Section 1. The sum of ^{3,629,525} \$1,200,000 is appropriated from the general fund
12 to the Department of Transportation and Public Facilities for payment as a
13 grant to the Dillingham City school district for school construction and
14 upgrade.

15 * Sec. 2. The sum of \$1,200,000 is appropriated from the general fund to
16 the Department of Transportation and Public Facilities for payment as a grant
17 to the Bristol Bay borough school district for school construction and up-
18 grade.

19 * Sec. 3. The sum of \$19,850,500 is appropriated from the general fund to
20 the Department of Transportation and Public Facilities for school construc-
21 tion and upgrade in the following amounts in the following regional educa-
22 tional attendance areas:

23 Southwest regional educational

24 attendance area

\$12,094,000

25 Lake-Peninsula regional educational

26 attendance area

7,756,500

27 * Sec. 4. This Act takes effect immediately in accordance with AS 01.10.-
28 070(c).

29

DILLINGHAM CITY SCHOOL DISTRICT

POST OFFICE BOX 202
DILLINGHAM, ALASKA 99576

HERBERT OBA HARRY E. PURDY
PHONE: 842-3624 SUPERINTENDENT OF SCHOOLS ASSISTANT SUPERINTENDENT February 25, 1980

The Honorable Nels Anderson, Jr.
House of Representatives
Pouch V - State Capitol Building
Juneau, AK 99811

RE: Remodeling of Dillingham
High School

Dear Representative Anderson:

Let me start by thanking you for all of your hard work in the past in helping to provide Dillingham with new showers, gym and the funds to begin and complete a new elementary building. For your information the plans will be going out to bid on the third of March.

As you will recall during the last session we were also looking for funds to remodel the current high school. That need is still with use and is more apparent than ever as the Fire Marshall's office in the person of Ray C. Isenberg, has issued the District a notification of fire hazards and an order to correct. There are some which are not difficult to comply with. Enclosed please find the four (4) page report. I have circled the items which will be costly and difficult to comply with from the finance point of view.

To continue you have a number of copies of the "Dillingham Secondary School Facilities Analysis" which was prepared in January, 1978. That document deals with our needs. However, to review page 44 with you, we have completed the shower and locker rooms. Still needed under "A" are the Public Toilets and Hallway between new gym and old building. The rejected bid for the toilets and hallway was \$366,000.

Representative Nels Anderson
Page 2
February 25, 1980

B. Science Lab	477,200
C. Learning Resource Center	759,400
D. Music	302,100
E. Art	251,800
F. Home Economics	201,500
G. Health Clinic	75,600
H. Classrooms	<u>465,500</u>
Jan. 1978 est.	\$2,899,100
Inflation 10.5 (1979)	
8.9 (1980) = 19.4%	<u>562,425</u>
	\$3,461,525

Additionally from a safety stand point
and financial savings a sprinkler system
would be needed.

	<u>168,000</u>
	\$3,629,525


We have asked that a sprinkler system be installed as an add-on in the bids for the new elementary and have looked into the cost. For the building which is about one-half the square foot of the high school is about \$56,000 and since adding the system to the high school which is about 44,000 square feet the cost would be three times the cost for the new elementary. The savings on insurance is great, (for example: the cost for \$1,000 of insurance without the system is \$1.25 and with the system \$.50 for \$1,000 of insurance or a savings of \$.75 per \$1,000 of insurance.) The high school, not counting the gym and showers, is valued at \$4,000,000. As you can see there is a great deal of savings.

The District could get by with \$3,629,000. It would be greatly appreciated by the community, board and administration of the District if you could secure the funds to complete our school construction and remodeling program.

Please let us know in what ways we would be of help.

Thank you again for your help.

Sincerely,



Harry E. Purdy
Assistant Superintendent

HEP:mkt

Enclosure: 2

PAGE #1

STATE OF ALASKA

JAY S. HAMMOND, GOVERNOR

DEPARTMENT OF PUBLIC SAFETY

DIVISION OF FIRE PREVENTION

P. O. BOX 6188, ANNEX
ANCHORAGE, ALASKA 99502

NOTIFICATION OF FIRE HAZARDS AND AN ORDER TO CORRECT

To: MR HERBERT ODE Occupancy Name: DILLINGHAM High School
SUPERINTENDENT Location: DILLINGHAM
DILLINGHAM School Dist Survey Date: 1-15-80
P.O. Box 002 UBC Classification: C-1
DILLINGHAM AK 99576 Surveyor: ISENBERG

The following deficiencies were noted and are required to be corrected as indicated:

Deficiencies	Corrective action required	Correct by
1. PARTITIONS 4 FEET IN HEIGHT FORMING CORRIDORS	PERMANENT PARTITIONS (WALLS) IN EVERY CLASS ROOM ARE REQUIRED TO EXTEND FROM FLOOR TO CEILING OR OPENINGS AT TOP OF WALL. IBC SECTION 3304 (a)	MARCH 15, 1980
2. CLASS ROOM DOORS FULLY CORE:	DOORS TO CLASS ROOMS ARE REQUIRED TO BE 20 MINUTE RATED SMOKE STOP DOORS IBC SECTION 3304 (4)(v)	MARCH 15, 1980

A LETTER CERTIFYING THAT THE LISTED DEFICIENCIES HAVE BEEN CORRECTED SHALL BE SENT TO THIS OFFICE WITHIN TEN (10) DAYS FOLLOWING THE DATE (S) SPECIFIED IN COLUMN THREE.

Received by: Herbert Ode
 Relation to Property _____
 Please reply to: _____

ORDER OF THE STATE FIRE MARSHALL
 By: Ray C. Seabury
 (Surveyor)
 Date: Jan 15, 1980

*Indicates deficiency pending from previous survey.

Authority: AS 18.70.070
AS 18.70.080
AS 18.70.090

- | | | |
|---|---|--------------------------------|
| 3. OPENING INTO
CORRIDOR - OLD
Radio Room Plain
GLASS - | INSTALL 1/4" THICK
WIRED GLASS SET IN
STEEL FRAMES
ULC SEC. 3304 (h) | MARCH 15, 1980 |
| 4 WEST EXIT DOOR
OBSTRUCTED BY
DESK | REMOVE OBSTRUCTION
FROM EXIT DOOR AND
MAINTAIN REQUIRED WIDTH
ULC SEC. 3301 (a) | UPON RECEIPT OF
THIS NOTICE |
| 5 PORTABLE FIRE
EXTINGUISHERS
THROUGH OUT
SCHOOL REQUIRE
CHECKING | HAVE ALL FIRE
EXTINGUISHERS CHECKED
AND SERVICED IF
NEEDED.
NFPA 10 & 104 | MARCH 15, 1980 |
| 6. Radio Room and
CLASS ROOMS | REMOVE ALL STYROFOAM
FROM TOP OF PARTITIONS
AND COMPLETE CONSTRUCTION
OF WALL TO CEILING.
13 AIC - SO. 070 (1)(a) | MARCH 15, 1980 |
| 7. Radio Room
STORAGE | LOWER STORAGE AND
MAINTAIN 18" CLEARANCE
FROM CEILING | MARCH 15, 1980 |

H. W. O.
Owner/Operator (Initial)

J. H.
Surveyor (Initial)

MARCH 15, 1980
Date

D. C. LINGHAM High School
Occupancy (Name)

Page 2 of 4

8. CEILING TILE MISSING THROUGHOUT SCHOOL	REPLACE ALL CEILING TILE WHERE MISSING	MARCH 15, 1980
9. FLAME SPREAD REQUIREMENTS OF CORRIDOR WOOD PANELS - LETTER REQUIRED CERTIFYING PANEL MEET CODE.	WOOD PANEL WORK IN CORRIDOR REQUIRED TO HAVE FLAME SPREAD RATING (B) FLAME SPREAD CLASSIFICATION 26-75 - UBC SEC. 4003 TABLE 42-A.	MARCH 15, 1980
10. OLD BOILER ROOM.	REPLACE ELECTRICAL PANEL BOX COVER. NEC.	MARCH 15, 1980
11. MAINTS SHOP DOOR.	INSTALL SELF CLOSING DEVICE FOR MAINTS SHOP DOOR	MARCH 15, 1980
12. EMERGENCY EXIT LIGHT BY OLD CUM NOT WORKING PROPERLY.	REPAIR OR REPLACE BATTERY IN EMERGENCY LIGHT UBC SECTION 3312(a)	MARCH 15, 1980

H.H.O.ber

Owner/Operator (Initial)

Dke

Surveyor (Initial)

JAN 15, 1980

Date

Dillingham High School

Occupancy (Name)

Page 3 of 4

13. EXIT LIGHTS THROUGHOUT	REPLACE EXIT LIGHT BULBS WHERE NEEDED UBC SECTION 3312 (C)	UPON RECEIPT OF THIS NOTICE
14. METAL SHOP OXYGEN BOTTLES	OXYGEN BOTTLES ARE REQUIRED TO BE CHAINED TO WALL	MARCH 15, 1980
15. DRAFTING ROOM 2ND FLOOR REQUIRES SECOND EXIT.	INSTALL EXIT DIRECT TO EXTERIOR OF BLDG EXIT FROM DRAFTING ROOM NOT TO PASS THROUGH METAL SHOP OR WOOD WORKING SHOP. UBC 3302 (a) UBC SECTION 3302 (E)	MARCH 15, 1980
16. SEPARATION REQUIRED BETWEEN WOOD WORKING AND METAL SHOPS.	WALL BETWEEN WOOD AND METAL SHOPS IS REQUIRED TO BE 5/8 TYPE X GYPSUM WALLBOARD TO BOTH SIDES OF 2" X 4" 16" ON CENTER TYPED & FINISHED UBC SEC. 803 (D)	MARCH 15, 1980

W. W. [Signature]
Owner/Operator (Initial)

[Signature]
Surveyor (Initial)

JAN 15, 1980
Date

DILLINGHAM High
Occupancy (Name)

Page

4

of

4